

Specification of the boilers:

Brand	Gassero	Blaudens	Meksis	Cropina	Scirocco	Strada
Model	Wallcon X-treme 42	Innodens X-treme 42	MKDT X-treme 42	Cropina Wall X-treme 42	Scirocco Wall X-treme 42	Strada Wall X-treme 42
Model	Wallcon X-treme 50	Innodens X-treme 50	MKDT X-treme 50	Cropina Wall X-treme 50	Scirocco Wall X-treme 50	Strada Wall X-treme 50
Model	Wallcon X-treme 67	Innodens X-treme 67	MKDT X-treme 67	Cropina Wall X-treme 67	Scirocco Wall X-treme 67	Strada Wall X-treme 67
Model	Wallcon X-treme 115	Innodens X-treme 115	MKDT X-treme 115	Cropina Wall X-treme 115	Scirocco Wall X-treme 115	Strada Wall X-treme 115
Model	Wallcon X-treme 125	Innodens X-treme 125	MKDT X-treme 125	Cropina Wall X-treme 125	Scirocco Wall X-treme 125	Strada Wall X-treme 125
Model	Wallcon X-treme 150	Innodens X-treme 150	MKDT X-treme 150	Cropina Wall X-treme 150	Scirocco Wall X-treme 150	Strada Wall X-treme 150
Model	Wallcon 42	Innodens 42	MKDT 42	Cropina Wall 42	Scirocco Wall 42	Strada Wall 42
Model	Wallcon 50	Innodens 50	MKDT 50	Cropina Wall 50	Scirocco Wall 50	Strada Wall 50
Model	Wallcon 67	Innodens 67	MKDT 67	Cropina Wall 67	Scirocco Wall 67	Strada Wall 67
Model	Wallcon 115	Innodens 115	MKDT 115	Cropina Wall 115	Scirocco Wall 115	Strada Wall 115
Model	Wallcon 125	Innodens 125	MKDT 125	Cropina Wall 125	Scirocco Wall 125	Strada Wall 125
Model	Wallcon 150	Innodens 150	MKDT 150	Cropina Wall 150	Scirocco Wall 150	Strada Wall 150

Brand	Scopula	Exinox	Firefox	Baccara	Expance	Schahane
Model	Scopula Wall X-treme 42	Exinox Wall X-treme 42	Firefox Wall X-treme 42	Baccara Wall X-treme 42	Expance Wall X-treme 42	Schahane Wall X-treme 42
Model	Scopula Wall X-treme 50	Exinox Wall X-treme 50	Firefox Wall X-treme 50	Baccara Wall X-treme 50	Expance Wall X-treme 50	Schahane Wall X-treme 50
Model	Scopula Wall X-treme 67	Exinox Wall X-treme 67	Firefox Wall X-treme 67	Baccara Wall X-treme 67	Expance Wall X-treme 67	Schahane Wall X-treme 67
Model	Scopula Wall X-treme 115	Exinox Wall X-treme 115	Firefox Wall X-treme 115	Baccara Wall X-treme 115	Expance Wall X-treme 115	Schahane Wall X-treme 115
Model	Scopula Wall X-treme 125	Exinox Wall X-treme 125	Firefox Wall X-treme 125	Baccara Wall X-treme 125	Expance Wall X-treme 125	Schahane Wall X-treme 125
Model	Scopula Wall X-treme 150	Exinox Wall X-treme 150	Firefox Wall X-treme 150	Baccara Wall X-treme 150	Expance Wall X-treme 150	Schahane Wall X-treme 150
Model	Scopula Wall 42	Exinox Wall 42	Firefox Wall 42	Baccara Wall 42	Expance Wall 42	Schahane Wall 42
Model	Scopula Wall 50	Exinox Wall 50	Firefox Wall 50	Baccara Wall 50	Expance Wall 50	Schahane Wall 50
Model	Scopula Wall 67	Exinox Wall 67	Firefox Wall 67	Baccara Wall 67	Expance Wall 67	Schahane Wall 67
Model	Scopula Wall 115	Exinox Wall 115	Firefox Wall 115	Baccara Wall 115	Expance Wall 115	Schahane Wall 115
Model	Scopula Wall 125	Exinox Wall 125	Firefox Wall 125	Baccara Wall 125	Expance Wall 125	Schahane Wall 125
Model	Scopula Wall 150	Exinox Wall 150	Firefox Wall 150	Baccara Wall 150	Expance Wall 150	Schahane Wall 150

Brand	Rinnai	MHG Gassero
Model	AIM X-treme 42 M	Wallcon X-treme 42
Model	AIM X-treme 50 M	Wallcon X-treme 50
Model	AIM X-treme 67 M	Wallcon X-treme 67
Model	AIM X-treme 115 M	Wallcon X-treme 115
Model	AIM X-treme 125 M	Wallcon X-treme 125
Model	AIM X-treme 150 M	Wallcon X-treme 150
Model	AIM 42 M	Wallcon 42
Model	AIM 50 M	Wallcon 50
Model	AIM 67 M	Wallcon 67
Model	AIM 115 M	Wallcon 115
Model	AIM 125 M	Wallcon 125
Model	AIM 150 M	Wallcon 150





Strojirenský zkušební ústav, s.p., Brno, Česká republika
Notifikovaná osoba 1015
Engineering Test Institute, Public Enterprise, Brno, Czech Republic
Notified Body 1015

CERTIFIKÁT ES PŘEZKOUŠENÍ TYPU EC TYPE-EXAMINATION CERTIFICATE

podle směrnice 92/42/EHS (účinnost teplovodních kotlů)
pursuant to Directive 92/42/EEC (Boiler efficiency)

Číslo:
Number: **E-30-00663-18**

Držitel certifikátu – výrobce:
Owner of Certificate –
Manufacturer: Gassero Isı Teknolojileri Sanayi Limited Şirketi
İstanbul Endüstri ve Ticaret Serbest Bölgesi (FREE ZONE)
4. Sokak, Parsel No. 110, 34957 Tuzla, İstanbul
Turecko – Turkey

Výrobek:
Product: Kondenzační teplovodní kotel na zemní plyn (G20)
Condensing hot-water boiler burning natural gas (G20)

Typové označení:
Type designation: Gassero, Blaudens, Meksis, Cropina, Scirocco, Strada,
Scopula, Exinox, Firefox, Baccara, Expanse, Schahane,
Rinnai, MHG Gassero

Obchodní označení:
Trade mark: je uvedeno na 2. straně
see Page 2

Podklad pro vydání certifikátu:
Basis of Certificate issuance: Závěrečný protokol č. 30-13500 ze dne 2018-05-31
Final Report 30-13500 of 2018-05-31

Strojirenský zkušební ústav, s.p., Notifikovaná osoba 1015, potvrzuje, že výše uvedené výrobky splňují požadavky na účinnost kotlů podle směrnice 92/42/EHS (nařízení vlády č. 25/2003 Sb.). Nedílnou součástí certifikátu je závěrečný protokol, který obsahuje závěry zkoušky, údaje pro identifikaci schváleného typu a seznam příslušné části technické dokumentace.

Strojirenský zkušební ústav, s.p. (Engineering Test Institute, Public Enterprise), Notified body 1015, hereby confirms that the above-mentioned products fulfil the efficiency requirements for boilers according to Directive 92/42/EEC (Government Regulation 25/2003 Coll.). An integral part of the Certificate is the Final Report comprising verification findings, data on the approved type identification and the list of the relevant part of the technical documentation.

Brno, 2018-05-31




Ing. Aleš Onderek
zástupce ředitele
Deputy Director

E-30-00663-18, strana – page 1 (2)

Strojirenský zkušební ústav, s.p., Hudcova 424/56b, 621 00 Brno, Česká republika
Engineering Test Institute, public enterprise, Hudcova 424/56b, 621 00 Brno, Czech Republic

www.szutest.cz



PRAVIDLA PRO NAKLÁDÁNÍ S CERTIFIKÁTEM A PODMÍNKY JEHO PLATNOSTI

Splnění požadavků nařízení Evropského parlamentu a Rady (EU) 2016/426 bylo odvozeno ze splnění požadavků použitých norem, které jsou uvedeny v závěrečném protokolu (tj. hodnotící zprávě). Novelizace některého z uvedených normativních dokumentů, zejména novelizace norem nebo vydání nových norem, může změnit skutečnosti, za kterých byl certifikát vydán. V takovém případě je třeba použitelnost certifikátu přezkoumat.

Oznámený subjekt dbá na to, aby byl informován o všech změnách obecně uznávaného stavu techniky, které by naznačovaly, že schválený typ již nemusí být v souladu s příslušnými požadavky tohoto nařízení, a rozhodne, zda tyto změny vyžadují doplňující šetření. Pokud šetření vyžadují, oznámený subjekt o tom informuje výrobce.

Výrobce informuje oznámený subjekt, který uchovává technickou dokumentaci týkající se certifikátu EU přezkoušení typu, o všech úpravách schváleného typu, které mohou ovlivnit shodu spotřebiče nebo vybavení se základními požadavky tohoto nařízení nebo podmínky platnosti certifikátu. Tyto úpravy vyžadují dodatečné schválení formou dodatku k původnímu certifikátu EU přezkoušení výrobního typu.

Certifikát se může používat pouze jako certifikát výrobku, jehož specifikace je uvedena na 1. až 4. straně. To platí i pro použití v reklamních, propagačních a komerčních materiálech. Neoprávněné nebo klamavé použití certifikátu může být sankcionováno.

Je zakázáno měnit, doplňovat nebo přepisovat údaje v certifikátu.

Certifikátem nelze dokládat vlastnosti výrobku, u kterého byla provedena bez souhlasu Strojírenského zkušebního ústavu, s.p., změna ovlivňující shodu s použitými normami a technickými předpisy.

Certifikační orgán požaduje, aby držitel certifikátu vedl záznamy o všech stížnostech a opatřeních k nápravě, které se týkají výrobků, na něž se vztahuje tento certifikát.

RULES FOR USING THE CERTIFICATE AND CONDITIONS OF ITS VALIDITY

Fulfilment of the requirements of Regulation (EU) 2016/426 of the European Parliament and of the Council has been derived from fulfilment of the requirements of the applied standards that are listed in the Final Report (i.e. evaluation report). Amendment of any of the mentioned normative documents, in particular amendments of standards or issuance of new standards, may change the facts and conditions, under which the present Certificate has been issued. In such a case, the applicability of the Certificate must be reviewed.

The Notified Body shall keep itself informed of any changes in the generally acknowledged state of the art, which indicate that the approved type may no longer comply with the applicable requirements of this Regulation, and shall decide whether such changes require further investigation. If so, the Notified Body shall inform the Manufacturer accordingly.

The Manufacturer shall inform the Notified Body that holds the technical documentation relating to the EU type-examination certificate of all modifications to the approved type that may affect the conformity of the appliance or fittings with the essential requirements of this Regulation or the conditions for validity of the Certificate. Such modifications shall require additional approval in the form of an addition to the original EU type-examination certificate – production type.

This Certificate may only be used as a certificate for the product specified on Pages 1, 2, 3 and 4. This also applies to its use in advertising, promotional and commercial materials. Unauthorised or deceptive use of the Certificate may be sanctioned.

It is prohibited to change, amend or overwrite the data contained in the Certificate.

The Certificate may not be used for documenting the properties of the product changed without consent of the Engineering Test Institute, Public Enterprise, in such a way that conformity with the applied standards and technical regulations has been affected.

Certification Body requires the holder of this Certificate to keep records of all the complaints and corrective actions relating to the products covered by this Certificate.





Technical data of the boilers:

Model	Heat input [kW]	Heat output [kW]		Maximum water temperature for central heating [°C]	Dimensions [mm]
		at 80/60 °C	at 50/30 °C		
Wallcon 42	7,2 - 39,4	7,0 - 38,3	7,6 - 41,3	80	446 x 390 x 654
Wallcon X-treme 42	7,2 + 39,4	7,0 + 38,3	7,6 + 41,3	80	485 x 490 x 612
Wallcon 50	8,4 + 48,0	8,1 + 46,3	8,9 + 50,1	80	446 x 390 x 654
Wallcon X-treme 50	8,4 + 48,0	8,1 + 46,3	8,9 + 50,1	80	485 x 490 x 612
Wallcon 67	11,2 - 63,0	11,0 - 61,0	12,0 - 67,0	80	446 x 480 x 654
Wallcon X-treme 67	11,2 - 63,0	11,0 - 61,0	12,0 - 67,0	80	485 x 490 x 612
Wallcon 115	27,0 + 108,5	26,1 + 105,4	29,3 + 115,5	80	558 x 580 x 865
Wallcon X-treme 115	27,0 + 108,5	26,1 + 105,4	29,3 + 115,5	80	558 x 580 x 865
Wallcon 125kW	17,0 + 121,0	16,6 + 116,2	18,4 + 126,0	80	558 x 580 x 865
Wallcon X-treme 125	17,0 + 121,0	16,6 + 116,2	18,4 + 126,0	80	558 x 580 x 865
Wallcon 150	21,0 - 143,0	19,5 - 138,0	22,7 - 150,0	80	558 x 690 x 865
Wallcon X-treme 150	21,0 - 143,0	19,5 - 138,0	22,7 - 150,0	80	558 x 580 x 865

Supply conditions:

Type	Product category	Supply pressures [mbar]	Gas used	Country of destination
B ₂₃ , C ₁₃ , C ₃₃ , C ₄₃ , C ₅₃ , C ₆₃ , C ₈₃	I _{2H}	20	G20	AT, CH, CZ, DK, EE, ES, FI, GB, GR, IE, IT, LT, LV, NO, PT, RO, SE, SI, SK, TR
	I _{2E}	20	G20	DE, LU, PL, RO
	I _{2H}	25	G20	HU



Specification of the boilers:

Brand	Gassero	Blaudens	Meksis	Cropina	Scirocco	Strada
Model	Wallcon X-treme 42	Innodens X-treme 42	MKDT X-treme 42	Cropina Wall X-treme 42	Scirocco Wall X-treme 42	Strada Wall X-treme 42
Model	Wallcon X-treme 50	Innodens X-treme 50	MKDT X-treme 50	Cropina Wall X-treme 50	Scirocco Wall X-treme 50	Strada Wall X-treme 50
Model	Wallcon X-treme 67	Innodens X-treme 67	MKDT X-treme 67	Cropina Wall X-treme 67	Scirocco Wall X-treme 67	Strada Wall X-treme 67
Model	Wallcon X-treme 115	Innodens X-treme 115	MKDT X-treme 115	Cropina Wall X-treme 115	Scirocco Wall X-treme 115	Strada Wall X-treme 115
Model	Wallcon X-treme 125	Innodens X-treme 125	MKDT X-treme 125	Cropina Wall X-treme 125	Scirocco Wall X-treme 125	Strada Wall X-treme 125
Model	Wallcon X-treme 150	Innodens X-treme 150	MKDT X-treme 150	Cropina Wall X-treme 150	Scirocco Wall X-treme 150	Strada Wall X-treme 150
Model	Wallcon 42	Innodens 42	MKDT 42	Cropina Wall 42	Scirocco Wall 42	Strada Wall 42
Model	Wallcon 50	Innodens 50	MKDT 50	Cropina Wall 50	Scirocco Wall 50	Strada Wall 50
Model	Wallcon 67	Innodens 67	MKDT 67	Cropina Wall 67	Scirocco Wall 67	Strada Wall 67
Model	Wallcon 115	Innodens 115	MKDT 115	Cropina Wall 115	Scirocco Wall 115	Strada Wall 115
Model	Wallcon 125	Innodens 125	MKDT 125	Cropina Wall 125	Scirocco Wall 125	Strada Wall 125
Model	Wallcon 150	Innodens 150	MKDT 150	Cropina Wall 150	Scirocco Wall 150	Strada Wall 150

Brand	Scopula	Exinox	Firefox	Baccara	Expanse	Schahane
Model	Scopula Wall X-treme 42	Exinox Wall X-treme 42	Firefox Wall X-treme 42	Baccara Wall X-treme 42	Expanse Wall X-treme 42	Schahane Wall X-treme 42
Model	Scopula Wall X-treme 50	Exinox Wall X-treme 50	Firefox Wall X-treme 50	Baccara Wall X-treme 50	Expanse Wall X-treme 50	Schahane Wall X-treme 50
Model	Scopula Wall X-treme 67	Exinox Wall X-treme 67	Firefox Wall X-treme 67	Baccara Wall X-treme 67	Expanse Wall X-treme 67	Schahane Wall X-treme 67
Model	Scopula Wall X-treme 115	Exinox Wall X-treme 115	Firefox Wall X-treme 115	Baccara Wall X-treme 115	Expanse Wall X-treme 115	Schahane Wall X-treme 115
Model	Scopula Wall X-treme 125	Exinox Wall X-treme 125	Firefox Wall X-treme 125	Baccara Wall X-treme 125	Expanse Wall X-treme 125	Schahane Wall X-treme 125
Model	Scopula Wall X-treme 150	Exinox Wall X-treme 150	Firefox Wall X-treme 150	Baccara Wall X-treme 150	Expanse Wall X-treme 150	Schahane Wall X-treme 150
Model	Scopula Wall 42	Exinox Wall 42	Firefox Wall 42	Baccara Wall 42	Expanse Wall 42	Schahane Wall 42
Model	Scopula Wall 50	Exinox Wall 50	Firefox Wall 50	Baccara Wall 50	Expanse Wall 50	Schahane Wall 50
Model	Scopula Wall 67	Exinox Wall 67	Firefox Wall 67	Baccara Wall 67	Expanse Wall 67	Schahane Wall 67
Model	Scopula Wall 115	Exinox Wall 115	Firefox Wall 115	Baccara Wall 115	Expanse Wall 115	Schahane Wall 115
Model	Scopula Wall 125	Exinox Wall 125	Firefox Wall 125	Baccara Wall 125	Expanse Wall 125	Schahane Wall 125
Model	Scopula Wall 150	Exinox Wall 150	Firefox Wall 150	Baccara Wall 150	Expanse Wall 150	Schahane Wall 150

Brand	Rinnai	MHG Gassero
Model	AIM X-treme 42 M	Wallcon X-treme 42
Model	AIM X-treme 50 M	Wallcon X-treme 50
Model	AIM X-treme 67 M	Wallcon X-treme 67
Model	AIM X-treme 115 M	Wallcon X-treme 115
Model	AIM X-treme 125 M	Wallcon X-treme 125
Model	AIM X-treme 150 M	Wallcon X-treme 150
Model	AIM 42 M	Wallcon 42
Model	AIM 50 M	Wallcon 50
Model	AIM 67 M	Wallcon 67
Model	AIM 115 M	Wallcon 115
Model	AIM 125 M	Wallcon 125
Model	AIM 150 M	Wallcon 150





Identification of the approved type:

Drawings:

- general drawings (boilers with cover) for models Wallcon 42 and Wallcon 50 named Wallcon 42 - 50 S, Wallcon 42 - 50 E
- drawings of boiler assembly for models Wallcon 42 and Wallcon 50 named Wallcon 42 - 50 S, Wallcon 42 - 50 E
- general drawings (boilers with cover) for model Wallcon 67 named Wallcon 67 S, Wallcon 67 E
- drawings of boiler assembly for model Wallcon 67 named Wallcon 67 S and Wallcon 67 E
- general drawings (boilers with cover) for models Wallcon 115 and Wallcon 125 named Wallcon 115 - 125 S and Wallcon 115 - 125 E
- drawings of boiler assembly for models Wallcon 115 and Wallcon 125 named Wallcon 115 - 125 S and Wallcon 115 - 125 E
- general drawings (boilers with cover) for model Wallcon 150 named Wallcon 150 S and Wallcon 150 E
- drawings of boiler assembly for model Wallcon 150 named Wallcon 150 S and Wallcon 150 E
- general drawings (boilers with cover) for models Wallcon X-TREME 42, Wallcon X-TREME 50 and Wallcon X-TREME 67 named Wallcon X-TREME 42-50-67 S, Wallcon X-TREME 42-50-67 E, Wallcon HERMETIC X-TREME 42-50-67 S and Wallcon HERMETIC X-TREME 42-50-67 E
- drawings of boiler assembly for models Wallcon X-TREME 42, Wallcon X-TREME 50 and Wallcon X-TREME 67 named Wallcon X-TREME 42-50-67 S, Wallcon X-TREME 42-50-67 E, Wallcon HERMETIC X-TREME 42-50-67 S and Wallcon HERMETIC X-TREME 42-50-67 E
- general drawings (boilers with cover) for models Wallcon X-treme 115 and Wallcon X-treme 125 named Wallcon X-treme 115 - 125 S and Wallcon X-treme 115 - 125 E
- drawings of boiler assembly for models Wallcon X-treme 115 and Wallcon X-treme 125 named Wallcon X-treme 115 - 125 S and Wallcon X-treme 115 - 125 E
- general drawings (boilers with cover) for model Wallcon X-treme 150 and named Wallcon X-treme 150 S and Wallcon X-treme 150 E
- drawings of boiler assembly for model Wallcon X-treme 150 named Wallcon X-treme 150 S and Wallcon X-treme 150 E
- drawing of the burner no: 34192 for models Wallcon 42 and Wallcon 50
- drawing of the burner No: 36445 for model Wallcon 67
- drawings of the burners No: 108.1568.01 and E0013129.dwg for models Wallcon X-TREME 42, Wallcon X-TREME 50 and Wallcon X-TREME 67
- drawing of the burner No: 45352 for models Wallcon 115, Wallcon 125, Wallcon X-treme 115 and Wallcon X-treme 125
- drawing of the burner No: 45345 for models Wallcon 150
- drawing of the burner No: 57097 for models Wallcon X-treme 150
- drawing of the heat exchanger assembly no: 035595 00 for models Wallcon 42 and Wallcon 50
- drawing of the heat exchanger assembly no: 42130 for model Wallcon 67
- drawing of the heat exchanger assembly no: 46844 for models Wallcon 115 and Wallcon 125
- drawing of the heat exchanger assembly no: 41130 for model Wallcon 150
- drawing of the heat exchanger assembly no: 12738 for models Wallcon X-TREME 42, Wallcon X-TREME 50 and Wallcon X-TREME 67
- drawing of the heat exchanger assembly no: 57339 for models Wallcon X-treme 115 and Wallcon X-treme 125
- drawing of the heat exchanger assembly no: 57328 for model Wallcon X-treme 150
- drawing of horizontal flue terminal Ø 80-125 mm No: B0142 P00 for models Wallcon 42, Wallcon 50, Wallcon 67, Wallcon X-TREME 42, Wallcon X-TREME 50 and Wallcon X-TREME 67
- drawing of vertical flue terminal Ø 80-125 mm No: B0139 P00 for models Wallcon 42, Wallcon 50, Wallcon 67, Wallcon X-TREME 42, Wallcon X-TREME 50 and Wallcon X-TREME 67
- drawing of flue fitting piece (adapter) Ø 80-80/125 mm No: A2659 P00 for models Wallcon 42, Wallcon 50, Wallcon 67, Wallcon X-TREME 42, Wallcon X-TREME 50 and Wallcon X-TREME 67
- drawing of flue fitting piece (adapter) Ø 80/125 mm No: 16053-001 R00 for models Wallcon X-TREME 42 and Wallcon X-TREME 50 and Wallcon X-TREME 67
- drawing of horizontal flue kit Ø 100-150 mm No: A2527 P01 for models Wallcon 115, Wallcon 125, Wallcon 150, Wallcon X-treme 115, Wallcon X-treme 125 and Wallcon X-treme 150
- drawing of vertical flue terminal Ø 100-150 mm No: A2481 P01 for models Wallcon 115, Wallcon 125, Wallcon 150, Wallcon X-treme 115, Wallcon X-treme 125 and Wallcon X-treme 150
- drawing of flue fitting piece (adapter) Ø 100-100/100-150 mm No: A2490 P01 for models Wallcon 115, Wallcon 125, Wallcon 150, Wallcon X-treme 115, Wallcon X-treme 125 and Wallcon X-treme 150

Installation, user and service manual





Strojírenský zkušební ústav, s.p., Brno, Česká republika
Oznámený subjekt identifikační číslo 1015
Engineering Test Institute, Public Enterprise, Brno, Czech Republic
Notified Body Identification Number 1015

CERTIFIKÁT EU PŘEZKOUŠENÍ TYPU EU TYPE-EXAMINATION CERTIFICATE

podle nařízení Evropského parlamentu a Rady (EU) 2016/426 ze dne 9. března 2016 o spotřebičích
plynných paliv

*pursuant to Regulation (EU) 2016/426 of the European Parliament and of the Council
of 9 March 2016 on appliances burning gaseous fuels*

Číslo:
Number: **E-30-00496-18**

Výrobce:
Manufacturer: Gassero ISI Teknolojileri Sanayi Limited Şirketi
Istanbul Endüstri ve Ticaret Serbest Bölgesi (FREE ZONE)
4. Sokak, Parsel No. 110, 34957 Tuzla, Istanbul
Turecko – Turkey

Identifikační číslo výrobků:
Product-ID-Number: **CE-1015CT0640**

Výrobek:
Product: Kondenzační teplovodní kotel na zemní plyn (G20)
Condensing hot-water boiler burning natural gas (G20)

Typové označení:
Type designation: Gassero, Blaudens, Meksis, Cropina, Scirocco, Strada,
Scopula, Exinox, Firefox, Baccara, Expanse, Schahane,
Rinnai, MHG Gassero

Obchodní označení:
Trade mark: je uvedeno na 3. straně
see Page 3

Identifikace schváleného typu:
Identification of approved type: je uvedena na 2. straně
see Page 2

Hodnoticí zpráva:
Evaluation Report: Závěrečný protokol č. 30-13500 ze dne 2018-05-31
Final Report 30-13500 of 2018-05-31

Strojírenský zkušební ústav, s.p., oznámený subjekt identifikační číslo 1015 potvrzuje, že předmětný výrobek splňuje požadavky podle bodu 1.4 Přílohy III nařízení Evropského parlamentu a Rady (EU) 2016/426 (modul B: EU přezkoušení typu). Výsledky činností provedených oznámeným subjektem jsou obsaženy v citovaném závěrečném protokolu (tj. hodnoticí zprávě). Údaje nezbytné k identifikaci schváleného typu jsou uvedeny na 2. straně tohoto certifikátu. Pravidla pro nakládání s certifikátem a podmínky jeho platnosti jsou uvedeny na 5. straně.


Tento certifikát je platný nejdéle do **2028-05-30**.

The Engineering Test Institute, Public Enterprise, Notified Body Identification Number 1015 hereby attests that the product concerned meets the requirements referred to in point 1.4 of Annex III of Regulation (EU) 2016/426 of the European Parliament and of the Council (Module B: EU type-examination). The results of the activities carried out by the Notified Body are contained in the cited Final Report (i.e. evaluation report). The data necessary for identification of the approved type are stated on Page 2 of this Certificate. The rules for using the Certificate and conditions of its validity are defined on Page 5.

This Certificate is valid until 2028-05-30.

Brno, 2018-05-31




Ing. Aleš Onderek
zástupce ředitele
Deputy Director

E-30-00496-18, Strana – Page 1/5

Strojírenský zkušební ústav, s.p., Hudcova 424/56b, 621 00 Brno, Česká republika
Engineering Test Institute, public enterprise, Hudcova 424/56b, 621 00 Brno, Czech Republic

www.szutest.cz

